

**MORONGO
BAND OF
MISSION
INDIANS**



A SOVEREIGN NATION

**MORONGO BAND OF MISSION INDIANS
BANNING, CALIFORNIA**

ADDENDUM NO. 5

EQUIPPING DOMESTIC WELL 7A & 8

GENERAL

All provisions of this Addendum No. 5 are hereby incorporated into the "MORONGO BAND OF MISSION INDIANS EQUIPPING OF DOMESTIC WELL 7A AND 8 and bidders shall account for all provisions pursuant to this Addendum No. 5 in submitting their bid proposals. **Each Bidder shall include a dated and signed copy of this Addendum No. 5 with the sealed bid proposal.**

Bidders are advised that the schedule for the above referenced project is hereby amended in the following manner and the following manner only:

ANSWERS TO QUESTIONS:

1. In Section 15162: Column pipe does not have a call out for it to be coated or non-coated, just says it needs to be NSF 61 certified. Does the column pipe required to be coated or non-coated?

Answer: Epoxy coating of the pump column pipe and suction pipe is not required.

2. During Well Chlorination and Disinfection. Will the water need to be captured and decanted, or can we utilize the pump to waste line that releases into the desert? We will need a copy of Morongo's NPDES permit to meet the constituents.

Answer: **Pump to waste line can be utilized.**

3. In Addendum #4, the updated **Section 15162 Deep Well Vertical Turbine Pumps, Part 2 – Products, 2.01 Pump Construction** calls for epoxy coating of the bowl assemblies, and epoxy coating and lining of the pump discharge heads and shaft enclosing tubes. I do not see a requirement for the pump column pipe nor the pump suction pipes to be epoxy coated and lined. Does the pump column pipe and suction pipe need to be epoxy coated and lined also?

Answer: Epoxy coating of the pump column pipe and suction pipe is not required.

4. Will chain link fence be barbed wire either only on the gates (as shown on detail sheet #9), or all throughout the fence, or none at all?

Answer: All gates and fence shall have barbed wire installed.

By: Shane Bloomfield
Shane Bloomfield (Engineer of Record)

Date: 11/12/24

ADDENDUM NO. 5 ACKNOWLEDGEMENT

Bidder hereby acknowledges receipt of Addendum No. 5 and the incorporation thereof in bid proposal for: MORONGO BAND OF MISSION INDIANS EQUIPPING OF DOMESTIC WELL NO. 7A AND 8 and bidders shall account for all provisions pursuant to this Addendum No. 5. **This acknowledgement page shall be signed, dated, and included with the Bid Proposal Packet.**

Contractor: _____

By: _____
(Contractor's Authorized Representative)

Date: _____

Title: _____